

# AP51 In-actuator Electronic Positioner- ac

---

## Introduction

The AP51 is designed to position a quarter turn electric actuator in sympathy with an incoming analogue command signal.

### **SAFETY !!**

#### **ELECTRIC SHOCK HAZARD**

*Always ensure control of the supply to the positioner and actuator.  
Dangerous voltages can be present with 230/115V supply equipment.*

#### **INJURY HAZARD**

*The actuator and associated mechanical equipment could operate in an unpredictable manner during initial operation and calibration. Appropriate precautions must be taken.*

## Declaration of Conformity



EMC Directive 89/336/EMC

Relevant Standards    EN50081-1 (Emissions)  
                                  EN50082-1 (Immunity)

This product has been successfully tested to the relevant parts of the above standards. In order to retain this conformity the user must fully comply with the wiring instructions.

Page 1 of 1

**Orange Instruments Ltd**

Owl Close, Moulton Park, Northampton, NN3 6HZ

Tel +44 (0)1604 790490 Fax +44 (0)1604 790690

[www.orangeinstruments.com](http://www.orangeinstruments.com)

e-mail [tony@orangeinstruments.demon.co.uk](mailto:tony@orangeinstruments.demon.co.uk)

Drawing Number: 9627

Issue: D

Date : 20/06/2002

File:I:\Current instruments 2007\AP51\HANDB\9627d.doc

Last Changed

23/11/07

### Operation Overview

The **AP51** is designed for the closed loop positioning of reversing actuators. The instrument compares two analogue signals, one representing the desired position (command signal) and the other representing the actual position (feedback signal) of the actuator. A difference between these two signals will cause the **AP51** outputs to operate, driving the actuator to the desired position. When the desired position is reached and link 1 is in, both outputs operate momentarily producing an electrical braking effect. With link 2 in, the actuator position will “freeze” on loss of command signal (4-20mA only). A positional Dead-Zone may be adjusted to overcome “hunting” problems associated with any mechanical overrun of the actuator.

### Physical

The **AP51** is normally mounted on a carrier plate and is fitted by the actuator supplier.

### Wiring

The **AP51** is supplied with 0.1” connectors for circuits within the actuator and screw terminals for external connections. Refer to the connector / terminal lists on Page 3.

To ensure conformance to the standards detailed above, please follow the guidelines below

*AN EARTH CONNECTION MUST ALWAYS BE MADE TO THE DESIGNATED EARTH TERMINAL.*

*An instrument earth connection is available within the actuator enclosure.*

*To ensure RFI compliance the analogue signals MUST be routed in copper braided screened cables with a fill factor density of at least 0.7.*

*The screens should be terminated to the metal of the actuator housing, ideally at a suitable metal cable gland.*

*Signal cables should be routed separately from power and switching conductors.*

*The use of a bulk supply filter on the general system supply is recommended.*

*Refer to the connections on Page 3 and the attached wiring diagram for layouts and terminal numbers. Always check wiring against the application-wiring diagram supplied with the actuator assembly.*

*Terminal capacity is 2.5 mm<sup>2</sup>. Do not strain the printed circuit board terminals when connecting the field wiring.*

**Connections** - these are included for completeness, the Manufacturer will normally undertake positioner to actuator wiring. Please consult the actuator handbook for customer wiring details.

There are three groups of connections on the AP51.

### **Group 1 – supply and signal terminals**

1	Re-transmitted position signal, positive	Red	0.25mm <sup>2</sup>	24Vdc
2	Re-transmitted position signal, negative	Purple	0.25mm <sup>2</sup>	24Vdc
3	Command signal, positive	Yellow	0.25mm <sup>2</sup>	24Vdc
4	Command signal, negative	Black	0.25mm <sup>2</sup>	24Vdc
5	Supply EARTH	Green/Yellow	0.5mm <sup>2</sup>	
6	Supply neutral / 115V selection Link 3	Blue	0.5mm <sup>2</sup>	24Vac/230Vac
7	115/230V selection Links 3, 1			
8	115/230V selection Links 2, 1			
9	Supply 115V selection Link 2			
10	Supply live	Brown	0.5mm <sup>2</sup>	24Vac/230Vac

For 24Vac operation - Fit no Links

For 115Vac operation - Fit Link 2 (8 to 9) and Link 3 (6 to 7) - ONLY

For 230Vac operation - Fit Link 1 (7 to 8) - ONLY

### **Group 2 – actuator motor and limit switches**

Connections are via a 0.1" pitch connector, wired by the manufacturer. DO NOT disconnect this group when power is supplied to the actuator. The connections are given for information only.

C	Actuator common connection	Blue	0.5mm <sup>2</sup>	24Vac/230Vac
D	Actuator decrease connection	Orange	0.5mm <sup>2</sup>	24Vac/230Vac
I	Actuator increase connection	Pink	0.5mm <sup>2</sup>	24Vac/230Vac
Hi	High limit – only for volt free limit switches	Purple	0.25mm <sup>2</sup>	5Vdc
Lo	Low limit – only for volt free limit switches	Orange	0.25mm <sup>2</sup>	5Vdc
COM	Common – only for volt free limit switches	Brown	0.25mm <sup>2</sup>	5Vdc

For actuators with live limit switches, i.e. those, which break the actuator motor, supply, Hi and Lo are linked to COM at the connector.

### **Group 3 – feed back potentiometer connections**

Connections are via a 0.1" pitch connector, wired by the manufacturer. DO NOT disconnect this group when power is supplied to the actuator. The connections are given for information only.

Mx	Feedback potentiometer Maximum	White	0.25mm <sup>2</sup>	5Vdc
Wp	Feedback potentiometer Wiper	Grey	0.25mm <sup>2</sup>	5Vdc
Mn	Feedback potentiometer Minimum	Green	0.25mm <sup>2</sup>	5Vdc

### **Special Notes for 24V ac units**

24V ac actuators typically use a small dc motor together with diode steering to give a reversing action. In order to operate correctly, the solid state switches on the AP51 have to be presented with a relatively low impedance load. 1K5 resistors are placed across the switches to provide this light loading. In addition, the motor commutator is rather noisy as it is operating on half wave rectified ac. A filter network is incorporated to minimise the effects of this electrical noise. All these components, the steering diodes, the load resistors and the filter are mounted on a small printed circuit board attached directly to the motor and connected to the AP51 and actuator limit switches by flying leads. This unit is normally installed by the actuator supplier.

### First time operation and calibration

#### **WARNING !!**

*The actuator and associated mechanical equipment connected to it could possibly move in an unpredictable manner during initial calibration. Ensure that all personnel take appropriate precautions. The calibration procedure involves the operation of printed circuit mounted switches. To avoid static body charge damage to the circuit board components, it is advisable to wear a purpose-built wrist-strap, grounded to earth via a 1M-ohm resistor.*

**Note that the AP51 is normally factory calibrated for its accompanying actuator and valve and should not require recalibration or any adjustments to linking.**

1. Ensure that end of travel limit switches and mechanical stops are correctly adjusted before operation.
2. Check the Manufacturer's delivery documents for supply and command signal details and compare this with site information.
  - a) Check that the AP51 supply selector is set to the site ac supply voltage (24V, 230V or 115V 50/60Hz).
  - b) Check that the command signal has been correctly specified. The calibration procedure described below assumes a "standard" 4-20mA-command signal. For other types or ranges of command signal, 4mA represents "minimum", 20mA "maximum" and 12mA 50% of the command signal used
2. Wire the actuator to a suitable supply. Connect a suitable command signal source, set at 12mA. Connect a DVM on a 0-200mA range, to measure the re-transmitted signal.
3. Switch on power. The actuator may travel to a limit or settle at an intermediate position. It is possible that the actuator might "hunt" about a position.
4. Press and hold the Calibration Switch SW1. The nearby red LED will light. The LED will extinguish within a few seconds. Release SW1 and the LED will light continuously.
5. Use the actuator manual facilities to set the actuator at mid point of its normal travel. If a mechanical adjustment is not available, it is possible to move the actuator by adjusting the command signal to 11mA or less to drive down or 13mA or more to drive up.
6. Carefully loosen the actuator feedback potentiometer (check manufacturer's information for identification) and adjust until the LED flashes quickly. The potentiometer is now set centrally with respect to the mechanical travel of the actuator. Tighten the feedback potentiometer. Set the command signal to 4mA and check that the actuator travels to its minimum desired position and stops on the lower limit switch.
7. Press and hold the Calibration Switch until the LED extinguishes. Release the switch and the LED will flash once briefly every couple of seconds.
8. Adjust the on-board potentiometer RV1 such that the re-transmitted position signal, monitored on the DVM, reads 4mA.
9. Press the Calibration Switch and hold until the LED extinguishes. Release the switch and check that the LED lights continuously. Set the command signal to 20mA and check that the actuator travels to its maximum desired position and stops on the upper limit switch.
10. Press and hold the Calibration Switch until the LED extinguishes. Release the switch and the LED will flash twice briefly every couple of seconds.
11. Adjust the on-board potentiometer RV1 such that the re-transmitted position signal, monitored on the DVM, reads 20mA.
12. Press the Calibration Switch and hold until the LED extinguishes. The calibration procedure is now complete.
13. Set the command signal to 12mA. The actuator will move from the maximum position to around 75% of travel. Carefully turn the on-board potentiometer RV1 anticlockwise and check that the actuator gradually moves towards its mid point of travel. It will probably be necessary to wind RV1 back clockwise slightly to counter any instability in positioning. This Dead Zone adjustment can be made at any time during normal operation.

### Manual Operation

Outside the Calibration routine, there is no Manual facility on the AP51.

**Linking Options**

Link 1 IN - Electronic breaking on outputs is active.

Link 2 IN - Freeze option of command signal break (4-20mA only). Otherwise drive down on command signal break.

**Specification**

**COMMAND SIGNAL INPUT** - The following options are available, factory selected on order.

Current anywhere in the range 0 – 50mA. Voltage anywhere in the range 0 – 50Vdc.

Typical ranges are

4-20mA nominal 200R input impedance

0-10V nominal 360K input impedance (Ensure link 2 is out)

**ANALOGUE POSITION OUTPUT SIGNAL**

This signal is NOT galvanically isolated from the command signal and MUST NOT share a common ground in the users peripheral equipment.

4-20mA self powered, can drive up to 300R

**FEEDBACK SIGNAL INPUT**

Potentiometer 3-wire, any value greater than 1K. Continuous film track preferred.

**SWITCHED OUTPUTS**

Outputs have a common high side feed with separate switched open and close outputs

Solid state relay (SSR) 2A, 18-250VAC 50/60Hz (Isolated to 4000V rms)

**INSTRUMENT SUPPLY**

The following options are available:

115VAC +/-10%, 50/60Hz 3VA by terminal link selection – page 3.

230VAC +/-10%, 50/60Hz 3VA by terminal link selection – page 3.

24VAC +/-10%, 50/60Hz 3VA available on order.

**USER ADJUSTMENTS** - the following functions are available

Calibration pushbutton switch – SW1

Calibration indicator LED

Calibration / Dead Zone adjustment potentiometer RV1

**PERFORMANCE** - the following applies to the AP51 only, characteristics of the feedback element and actuator system response will have additional effects.

Conversion 10 bit max., normal conversion range (4-20mA) = 1 in 800.

O/P switch res. +/-1 bit theoretically, modified to up to +/-25% of span by dead band .

Accuracy (Theo.) 0.125% span based on conversion resolution of 1 in 3200.

Accuracy (actual) 0.5% span based on 25% turn down of feedback range.